

## Pielikums par izmantotajām ievaddatu vērtībām

\*Atbilstoši Ministru kabineta 2021.gada 8. aprīļa noteikumiem Nr.222 "Ēku energoefektivitātes aprēķina metodes un ēku energosertifikācijas noteikumi"

Grādudienas, kWh		Aprēķina periods, dienas		Iekštelpu temperatūra, °C		Āra vides temperatūra, °C	
Zona Nr.1	Zona Nr.2	Zona Nr.1	Zona Nr.2	Zona Nr.1	Zona Nr.2	Zona Nr.1	Zona Nr.2
109.81		7272	0	20.0	0.0	<b>4.90</b>	
						Zona Nr.1	Zona Nr.2
						20.0	
						4.90	
						303	
						210.7	
						624.5	

Iekštelpu vidējā temperatūra periodā: °C  
 Āra vides vidējā temperatūra periodā: °C  
 Novērtējuma periods: dienas  
 References platība: m<sup>2</sup>  
 References tilpums: m<sup>3</sup>

### 1. Siltuma pārnese ar pārvadi

Norobežošā konstrukcijas tips	Konstrukcijas laukums	Konstrukcijas siltumcaurlaidība	Termiskā tilta garums/skaits	Termiskā tilta siltumcaurlaidība	Siltuma zudumi	Perioda ilgums	Temperatūras starpība	Siltuma pārnese ar pārvadi
	m <sup>2</sup>	W/(m <sup>2</sup> K)	m, gab	W/m vai W/gab	W/K	h	K	kWh gadā
1	2	3	4	5	6	7	8	9
Ārsienas	310.11	0.19			58.6	7272	15.10	6433
Pārsēgums	116.42	0.16	58.2	0.04	21.0	7272	15.10	2308
Grīda uz grunts	116.42	<b>0.17</b>	58.2	<b>0.02</b>	20.8	7272	15.10	2281
Logi / stiklotās durvis	62.20	1.10	97.6	0.04	72.2	7272	15.10	7926
Durvis/lūkas/vārti	2.16	1.80	6.6	0.04	4.2	7272	15.10	456
<b>Kopējā siltuma pārnese ar pārvadi apkurei:</b>								<b>19404</b>

### 2. Siltuma pārnese ar ventilāciju:

Zonas Nr.	Ventilācijas sistēma	Aprēķina tilpums	Gaisa apmaiņas intensitāte	Darbības ilgums periodā	Ventilācijas siltuma zudumu koeficients*	Enerģijas atgūšanas vidējais rādītājs periodā	Piegādātā gaisa temperatūras starpība	Siltuma pārnese ar ventilāciju
		m <sup>3</sup>	1/h	h	W/K	%	K	kWh gadā
1	2	3	4	5	6	7	8	9
1	Dabiskā	624		7272	0.0	0.0	15.10	0
	Mehāniskā	624	0.401	7272	84.1	80.00	3.02	1846
	Infiltrācija	624	0.044	7272	9.2	0.0	15.10	1008
<b>Kopējā siltuma pārnese ar ventilāciju apkurei:</b>								<b>2854</b>

Piezīme\* Gaisa tilpuma siltumietilpība 0,336 W/(m<sup>3</sup>K), LVS ISO 52016-1 p.6.3.6.

### 3. Saules siltuma ieguvumi caur caurspīdīgām un necaurspīdīgām norobežošajām konstrukcijām:

Nr.p.k.	Novietojums	Caurspīdīgo konstrukciju laukums	Samazinājuma faktors	Stiklojuma vidējā g-vērtība	Starojuma intensitāte periodā	Saules siltuma ieguvumi	
		m <sup>2</sup>			kWh/m <sup>2</sup> gadā	kWh gadā	
1	2	3	4	5	6	7	
2.3.1.	Ziemeļi	27.18	0.52	0.50	201.03	1412	
2.3.2.	Austrumi	9.29	0.48	0.50	328.54	726	
2.3.3.	Dienvīdi	24.77	0.57	0.50	494.16	3490	
2.3.4.	Rietumi	0.96	0.35	0.50	438.79	73	
2.3.5.	Horizontāli	0.00	0.00	0.00	675.14	0	
2.3.6.	Necaurspīdīgās norobežošās konstrukcijas						1326
<b>Kopējie saules siltuma ieguvumi apkurei:</b>						<b>7028</b>	

### 4. Iekšējie siltuma ieguvumi:

Zona Nr.	Apkures perioda ilgums	Īpatnējā iekšējo siltuma ieguvumu jauda**	References platība	Iekšējie siltuma ieguvumi
	h gadā	W/m <sup>2</sup>	m <sup>2</sup>	kWh gadā
1	2	3	4	5
1	7272	3.12	210.7	4781

### 5. Iekšējo siltuma ieguvumu izmantošanas koeficients

		kWh/m <sup>2</sup> gadā	kWh gadā
6.	Gada energoprasība apkurei:	<b>58.89</b>	<b>12409</b>

# Specific energy for heating (monthly method)

Energy balance calculation with PHPP Version 9.6a

Dzīvojamā māja / Climate: Rīga / TFA: 211 m<sup>2</sup> / Heating: 58.9 kWh/(m<sup>2</sup>a) / Freq. overheating: 2 % / PER: 131.8 kWh/(m<sup>2</sup>a)

The sum of the heating periods calculated through the monthly method will be presented on this side.

Interior temperature:	20	°C
Building type:	Dzīvojamā māja	
Treated floor area A <sub>TFA</sub> :	210.7	m <sup>2</sup>
Spec. Capacity:	116	Wh/(m <sup>2</sup> K)

Building assembly	Temperature zone	Area m <sup>2</sup>	U-Value W/(m <sup>2</sup> K)	Month. red. fac.	G <sub>i</sub> kWh/a	=	kWh/a	Per m <sup>2</sup> of treated floor area kWh/(m <sup>2</sup> a)	
External wall - Ambient	A	310.1	0.189	1.00	110	=	6433	30.53	
External wall - Ground	B			1.00		=			
Roof/Ceiling - Ambient	A	116.4	0.161	1.00	110	=	2052	9.74	
Floor slab / Basement ceiling	B	116.4	0.298	1.00	62	=	2138	10.14	
	A			1.00		=			
	A			1.00		=			
Pret neapkurināmu telpu	X			0.50		=			
Windows	A	62.2	1.098	1.00	110	=	7498	35.58	
Exterior door	A	2.2	1.800	1.00	110	=	427	2.03	
Exterior TB (length/m)	A	162.4	0.040	1.00	110	=	713	3.38	
Perimeter TB (length/m)	P	58.2	0.040	1.00	62	=	143	0.68	
Ground TB (length/m)	B			1.00		=		0.00	
Total								19404	92.1

## Transmission heat losses Q<sub>T</sub>

Effective air change rate Ambient n <sub>V,e</sub>	0.401	*(1 - 0%)	*(1 - 0.80)	+ 0.044	=	0.124			
Effective air change rate Ground n <sub>V,g</sub>	0.401	*(1 - 0%)	*(1 - 0.80)		=	0.000			
Effective air volume V <sub>V</sub> m <sup>3</sup>	211	* 2.96			=	624			
Ventilation losses ambient Q <sub>V</sub> kWh/a	624	* 0.124	* 0.336	* 110	=	2854	13.5		
Ventilation losses ground Q <sub>V,e</sub> kWh/a	624	* 0.000	* 0.336	* 83	=	0	0.0		
Total								2854	13.5

## Ventilation heat losses Q<sub>V</sub>

Total heat losses Q <sub>L</sub> kWh/a	( 19404 + 2854 )	* 1.0	=	22259	105.6
----------------------------------------	------------------	-------	---	-------	-------

## Total heat losses Q<sub>L</sub>

Orientation of the area	Reduction factor see 'Windows' worksheet	g-Value (perp. radiation)	Area m <sup>2</sup>	Global radiation kWh/(m <sup>2</sup> a)	=	kWh/a		
North	0.52	0.50	27.2	201	=	1412		
East	0.48	0.50	9.3	329	=	726		
South	0.57	0.50	24.8	494	=	3490		
West	0.35	0.50	1.0	439	=	73		
Horizontal	0.00	0.00	0.0	675	=	0		
Sum opaque areas					=	1326		
Total							7028	33.4

## Available solar heat gains Q<sub>S</sub>

Internal heat gains Q <sub>I</sub> kWh/a	0.024	* 303	* 3.1	* 210.7	=	4781	22.7	
Free heat Q <sub>F</sub> kWh/a					Q <sub>S</sub> + Q <sub>I</sub>	=	11809	56.0
Ratio free heat to losses					Q <sub>F</sub> / Q <sub>L</sub>	=	0.53	
Utilisation factor heat gains h <sub>c</sub>					=	83%		
Heat gains Q <sub>G</sub> kWh/a					η <sub>G</sub> * Q <sub>F</sub>	=	9849	46.7

## Heat gains Q<sub>G</sub>

Annual heating demand Q <sub>H</sub> kWh/a					Q <sub>L</sub> - Q <sub>G</sub>	=	12409	58.89
--------------------------------------------	--	--	--	--	---------------------------------	---	-------	-------

## Annual heating demand Q<sub>H</sub>

Limiting value kWh/(m <sup>2</sup> a)	-	Requirement met?	(Yes/No) -
---------------------------------------	---	------------------	------------

## Limiting value


# Specific energy for heating (monthly method)

Energy balance calculation with PHPP Version 9.6a

Dzivojamā māja / Climate: Riga / TFA: 211 m<sup>2</sup> / Heating: 58.9 kWh/(m<sup>2</sup>a) / Freq. overheating: 2 % / PER: 131.8 kWh/(m<sup>2</sup>a)

Interior temperature: **20** °C  
 Building type: **Dzivojamā māja**  
 Treated floor area A<sub>TFA</sub>: **211** m<sup>2</sup>

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating degree hours - External	16.9	15.3	14.5	9.9	6.2	3.4	1.2	1.9	5.3	9.8	12.8	15.8	113	kKh
Heating degree hours - Ground	7.9	7.7	8.5	7.5	6.5	4.9	2.2	1.5	3.1	3.9	5.0	6.6	65	kKh
Losses - Exterior	3069	2779	2631	1809	1121	611	225	352	971	1779	2333	2875	20555	kWh
Losses - Ground	291	286	315	278	240	180	80	55	113	145	186	246	2416	kWh
Sum spec. losses	15.9	14.5	14.0	9.9	6.5	3.8	1.4	1.9	5.1	9.1	12.0	14.8	109.0	kWh/m <sup>2</sup>
Solar gains - North	26	57	137	215	316	361	358	269	164	85	35	17	2039	kWh
Solar gains - East	14	30	69	111	166	174	171	137	87	48	17	10	1033	kWh
Solar gains - South	141	234	401	522	599	547	583	567	464	339	142	101	4640	kWh
Solar gains - West	2	4	7	11	15	15	16	13	9	5	2	1	102	kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar gains - Opaque	32	62	133	208	285	289	294	245	163	96	36	22	1864	kWh
Internal heat gains	489	442	489	473	489	473	489	489	473	489	473	489	5759	kWh
Sum spec. gains solar + internal	3.3	3.9	5.9	7.3	8.9	8.8	9.1	8.2	6.5	5.0	3.3	3.0	73.3	kWh/m <sup>2</sup>
Utilisation factor	100%	100%	100%	98%	71%	43%	16%	24%	77%	100%	100%	100%	68%	
Annual heating demand	2656	2238	1711	580	28	0	0	0	38	865	1813	2480	12409	kWh
Spec. heating demand	12.6	10.6	8.1	2.8	0.1	0.0	0.0	0.0	0.2	4.1	8.6	11.8	58.9	kWh/m <sup>2</sup>



## Annual heating demand: Comparison

Monthly method	(Heating)	<b>12409</b> kWh/a	<b>58.9</b> kWh/(m <sup>2</sup> a) reference to treated floor area according to PHPP
Annual method	(Annual heating)	<b>12635</b> kWh/a	<b>60.0</b> kWh/(m <sup>2</sup> a) reference to treated floor area according to PHPP

Stāvs	Numurs	Nosaukums	Kopējā			Apkurināmā				
			Platība, m <sup>2</sup>	Augstums, m	Tilpums, m <sup>3</sup>	TFA koef.	TFA, m <sup>2</sup>	TFV, m <sup>2</sup>	Tin, °C	Tin avg, °C
1	101	Halle	7.97	2.80	22.32	1	7.97	22.32	20.00	0.71
1	102	Garderobe	6.50	2.80	18.20	1	6.50	18.20	20.00	0.58
1	103	Tualete	3.52	2.80	9.86	1	3.52	9.86	20.00	0.32
1	104	Saimniecības telpa	11.88	2.80	33.26	1	11.88	33.26	20.00	1.07
1	105	Halle	20.08	2.80	56.22	1	20.08	56.22	20.00	1.80
1	106	Atpūtas telpa	27.30	4.37	119.30	1	27.30	119.30	20.00	3.82
1	107	Virtuve	24.05	2.80	67.34	1	24.05	67.34	20.00	2.16
1	108	Vējtveris	6.00	2.80	16.80	1	6.00	16.80	20.00	0.54
1	109	Tualete	2.75	2.80	7.70	1	2.75	7.70	20.00	0.25
1	110	Kabinets	16.50	2.80	46.20	1	16.50	46.20	20.00	1.48
1	111	Nojume	29.91			0				
1	112	Lievenis	6.96			0				
1	113	Terase	38.97			0				
2	201	Gaitenis	13.45	2.70	36.32	1	13.45	36.32	20.00	1.16
2	202	Vannas istaba	9.25	2.70	24.98	1	9.25	24.98	20.00	0.80
2	203	Guļamistaba	14.25	2.70	38.48	1	14.25	38.48	20.00	1.23
2	204	Guļamistaba	16.23	2.70	43.82	1	16.23	43.82	20.00	1.40
2	205	Guļamistaba	19.11	2.70	51.60	1	19.11	51.60	20.00	1.65
2	206	Garderobe	11.88	2.70	32.08	1	11.88	32.08	20.00	1.03
		<b>KOPĀ</b>	<b>286.56</b>	<b>2.96</b>	<b>624.46</b>		<b>210.72</b>	<b>624.46</b>		<b>20.00</b>

# Climate data

Dzīvojamā māja / Climate: Rīga / TFA: 211 m² / Heating: 58.9 kWh/(m²a) / Freq. overheating: 2 % / PER: 131.8 kWh/(m²a)

**Selection of climate data**

Country:

Region:

Climate data set:

Climate zone:

**Altitude**

Weather station:  m


Building location:  m

**Result overview**

Annual heating demand	58.9	kWh/(m²a)
Heating load	29.1	W/m²
Frequency of overheating	2.0	%
Sensible cooling	1.4	kWh/(m²a)
Latent cooling	0.0	kWh/(m²a)
Cooling load	-	W/m²
PER demand	131.8	kWh/(m²a)

**Data for heating**

Annual method	Heating	Cooling		
Heating / cooling period	223	303	153	d/a
Heating / cooling degree hours	95	110	-44	kKh/a
Radiation North	87	201	209	kWh/(m²a)
Radiation East	190	329	333	kWh/(m²a)
Radiation South	293	494	391	kWh/(m²a)
Radiation West	189	439	412	kWh/(m²a)
Horizontal radiation	313	675	704	kWh/(m²a)



	Month	Days												Heating load		Cooling load		PER factors	
		1	2	3	4	5	6	7	8	9	10	11	12	Weather 1	Weather 2	Weather 1	Weather 2		
	ud--01-Rīga	Latitude °	57.0	Longitude °	24.1	Altitude [m]	3	Daily temperature swing Summer [K]				8.4					Radiation: [W/m²]		
° C	Exterior temperature	-2.2	-2.2	1.2	6.9	12.4	16.0	18.9	17.9	13.1	7.3	2.6	-0.8	-12.8	-9.7	25.5	22.0	1.35	Household electri
kWh/(m²month)	Radiation North	4	8	18	28	40	47	46	35	22	12	5	2	4	4	106	60	1.25	Domestic hot wat
kWh/(m²month)	Radiation East	9	18	38	59	85	87	86	71	47	28	10	7	5	5	223	163	1.70	Heating
kWh/(m²month)	Radiation South	21	34	58	75	84	76	82	80	67	49	21	15	14	14	233	268	1.20	Cooling
kWh/(m²month)	Radiation West	8	17	38	62	88	90	91	74	47	26	10	6	7	7	223	163	1.20	Dehumidification
kWh/(m²month)	Horizontal radiation	11	25	63	110	160	164	166	133	81	41	14	7	10	10	350	230		
° C	Dew point temperature	-4.2	-5.0	-3.1	0.7	5.4	9.6	13.7	12.9	9.3	4.8	1.1	-2.4			16.7			
° C	Sky temperature	-12.0	-13.3	-11.9	-7.6	-1.4	2.5	7.6	7.8	2.7	-1.7	-5.8	-10.0			14.1	12.1		
° C	Ground temperature	9.4	8.5	8.5	9.6	11.3	13.2	17.1	18.0	15.8	14.7	13.0	11.1	8.5	8.5	18.0	18.0		
	Comment:	PHPP, LBN003-19																	

# U-value of building assemblies

Energy balance calculation with PHPP Version 9.6a

Dzīvojamā māja / Climate: Rīga / TFA: 211 m<sup>2</sup> / Heating: 58.9 kWh/(m<sup>2</sup>a) / Freq. overheating: 2 % / PER: 131.8 kWh/(m<sup>2</sup>a)

Secondary calculation: Equivalent thermal conductivity of still air spaces -> (on the right)

Wedge-shaped assembly layer -> (on the right)

Unheated / uncooled attic -> (on the right)

Assembly no.	Building assembly description					Interior insulation?
01ud	Ārsiena					
Orientation of building element		Heat transmission resistance [m <sup>2</sup> K/W]				
Adjacent to		interior R <sub>si</sub>	0.13			
2-Wall		exterior R <sub>se</sub>	0.04			
1-Outdoor air						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Iekšējā apdare	0.900					10
Keramzītbetona bloki	0.260					300
Minerālvate	0.038					150
Ārējā apdare	0.900					10
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						47.0 cm
U-value supplement		U-value:				0.189 W/(m <sup>2</sup> K)

Assembly no.	Building assembly description					Interior insulation?
02ud	Bēniņu pārsegums P1					
Orientation of building element		Heat transmission resistance [m <sup>2</sup> K/W]				
Adjacent to		interior R <sub>si</sub>	0.10			
1-Roof		exterior R <sub>se</sub>	0.10			
3-Ventilated						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Ģipškartons	0.250					25
Beramā siltumizolācija	0.048	Koka sijas	0.130			200
Beramā siltumizolācija	0.048					100
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
94%		6.0%				32.5 cm
U-value supplement		U-value:				0.161 W/(m <sup>2</sup> K)


Assembly no.	Building assembly description					Interior insulation?
03ud	Grīda uz grunts					
Orientation of building element		Heat transmission resistance [m <sup>2</sup> K/W]				
Adjacent to		interior R <sub>si</sub>	0.17			
3-Floor		exterior R <sub>se</sub>	0.00			
2-Ground						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Grīdas segums	0.500					10
Betona izlīdzinošais slānis	2.000					70
Putupolistirols	0.038					100
Blietētas šķembas	2.000					100
Blietēta grunts	2.000					900
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						118.0 cm
U-value supplement		U-value:				0.298 W/(m <sup>2</sup> K)

# Windows

Dzīvojamā māja / Climate: Rīga / TFA: 211 m<sup>2</sup> / Heating: 58.9 kWh/(m<sup>2</sup>a) / Freq. overheating: 2 % / PER: 131.8 kWh/(m<sup>2</sup>a)

Window area orientation	Global radiation (main orientations) kWh/(m <sup>2</sup> a)	Shading	Dirt	Non-vertical radiation incidence	Glazing fraction	g-Value	Solar irradiation reduction factor	Window area	Window U-Value	Glazing area	Average global radiation
Standard values →		0.75	0.95	0.85				m <sup>2</sup>	W/(m <sup>2</sup> K)	m <sup>2</sup>	kWh/(m <sup>2</sup> a)
North	87	0.81	0.95	0.85	0.79	0.50	0.52	27.18	1.10	21.39	93
East	190	0.79	0.95	0.85	0.75	0.50	0.48	9.29	1.12	6.94	155
South	293	0.86	0.95	0.85	0.82	0.50	0.57	24.77	1.09	20.27	287
West	189	0.74	0.95	0.85	0.58	0.50	0.35	0.96	1.18	0.56	224
Horizontal	313	1.00	0.95	0.85	0.00	0.00	0.00	0.00	0.00	0.00	313
Total or average value for all windows.						0.50	0.53	62.20	1.10	49.16	

Transmission losses heating period	Heating gains solar radiation heating period
kWh/a	kWh/a
2853	655
989	343
2570	2029
108	37
0	0
6520	3064



Recommendation for U<sub>w,installed</sub> [W/(m<sup>2</sup>K)]

0.65	0.70	0.80	0.44
------	------	------	------

Heating degree hours [Kk/a]: 95.5

[Go to glazing list](#) [Go to window frames list](#)

Quantity	Description	Deviation from north	Angle of inclination from the horizontal	Orientation	Window rough openings		Installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge (Avg.)	Installation situation				Ψ <sub>Installation</sub> (Avg.)	Results				
					Width	Height					Perpendicular radiation	Glazing		Frames (avg.)	user determined value for Ψ <sub>Installation</sub> OR '1': Ψ <sub>Installation</sub> from 'Components' worksheet '0' in the case of shuttling windows				Window Area	Glazing area	U <sub>w, installed</sub>	Glazed fraction per window	
															left	right	bottom						top
	Z	-	-		m	m		1-Sorting: LIKE LIST	1-Sorting: LIKE LIST	-	W/(m <sup>2</sup> K)	W/(m <sup>2</sup> K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m <sup>2</sup>	m <sup>2</sup>	W/(m <sup>2</sup> K)	%	
1	L3	-20	90	North	2.700	2.050	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	5.5	4.63	1.08	84%	
1	L4	-20	90	North	2.700	1.950	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	5.3	4.38	1.08	83%	
1	L5	-20	90	North	1.800	2.050	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	3.7	2.96	1.09	80%	
1	L6	-20	90	North	1.800	1.500	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	2.7	2.08	1.11	77%	
1	L9	-20	90	North	1.500	1.500	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	2.3	1.69	1.11	75%	
1	L10	-20	90	North	0.900	1.600	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	1.4	0.98	1.14	68%	
1	L11	-20	90	North	0.900	1.500	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	1.4	0.91	1.14	67%	
1	L13	-20	90	North	1.500	0.800	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	1.2	0.78	1.15	65%	
1	D1	-20	90	North	1.500	2.500	1-Z	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	3.8	2.99	1.10	80%	
	A																						
1	L5	70	90	East	1.800	2.050	2-A	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	3.7	2.96	1.09	80%	
1	L6	70	90	East	1.800	1.500	2-A	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	2.7	2.08	1.11	77%	
1	L12	70	90	East	2.500	0.800	2-A	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	2.0	1.38	1.14	69%	
1	L16	70	90	East	1.500	0.600	2-A	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	0.9	0.52	1.18	58%	
	D																						
1	L1	160	90	South	3.000	2.500	3-D	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	7.5	6.44	1.07	86%	
1	L2	160	90	South	3.000	2.400	3-D	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	7.2	6.16	1.07	86%	
1	L7	160	90	South	2.000	1.400	3-D	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	2.8	2.16	1.11	77%	
1	L8	160	90	South	1.600	1.500	3-D	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	2.4	1.82	1.11	76%	
1	L14	160	90	South	1.600	0.700	3-D	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	1.1	0.70	1.16	63%	
1	D2	160	90	South	1.500	2.500	3-D	01ud-3 stiklu pakete	01ud-Logu rāmis	0.50	1.01	1.10	0.035	1	1	1	1	0.000	3.8	2.99	1.10	80%	

## Ventilation data

Energy balance calculation with PHPP Version 9.6a

Dzīvokļa māja / Climate: Rīga / TFA: 211 m<sup>2</sup> / Heating: 58.9 kWh/(m<sup>2</sup>a) / Freq. overheating: 2 % / PER: 131.8 kWh/(m<sup>2</sup>a)

Treated floor area A <sub>TFA</sub>	m <sup>2</sup>	211	(Areas' worksheet)
Room height h	m	2.96	2.96
Volume of ventilated space (A <sub>TFA</sub> ·h) = V <sub>V</sub>	m <sup>3</sup>	624	(Worksheet 'Annual heating')

### Ventilation type

Please select **1-Balanced PH ventilation with HR**

### Infiltration air change rate

Wind protection coefficients e and f			
Coefficient e for wind protection class	Several side exposed	One side exposed	
No protection	0.10	0.03	
Moderate protection	0.07	0.02	
High protection	0.04	0.01	
Coefficient f	15	20	
	For annual demand:	For heating load:	
Wind protection coefficient, e	0.03	0.08	
Wind protection coefficient, f	20	20	Net air volume for press. test V <sub>250</sub>
Air change rate at press. test n <sub>50</sub>	1/h	1.46	624 m <sup>3</sup>
	For annual demand:	For heating load:	Air permeability q <sub>50</sub>
Excess extract air	1/h	0.00	1.50 m <sup>3</sup> /(h·m <sup>2</sup> )
Infiltration air change rate n <sub>V,Rest</sub>	1/h	0.044	0.109

### Selection of ventilation input - Results

PHPP offers two methods for dimensioning air quantities and choosing the ventilation unit. With "Standard data input for balanced ventilation", supply or extract air quantities for residential buildings and parameters for ventilation systems with a maximum of 1 ventilation unit can be planned. Projects with up to 10 different ventilation units and air quantities determined according to rooms or zones can be entered in the 'Add'l vent' worksheet. Please select your design method here:

Ventilation unit / Heat recovery efficiency design	Average air flow rate m <sup>3</sup> /h	Average air change rate 1/h	Extract air excess (extract air system) 1/h	Effective heat recovery efficiency unit [%]	Humidity recovery efficiency [%]	Specific power input Wh/m <sup>2</sup>	Heat recovery efficiency SHX [%]
<input checked="" type="checkbox"/> Standard design (Ventilation' worksheet, see below)	250	0.40	0.00	80.0%	0.0%	0.30	0.0%
<input type="checkbox"/> Multiple ventilation units, non-res (Add'l vent' worksheet)							
				Cooling recovery		Efficiency SHX	0%

### Average interior humidity during winter operation

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
30%	29%	31%	38%	49%	61%	-	-	60%	47%	39%	32%

## Standard data input for balanced ventilation

Energy balance calculation with PHPP Version 9.6a

Dimensioning of ventilation system with only one ventilation unit

Occupancy	m <sup>2</sup> /P	42
Number of occupants	P	5.0
Supply air per person	m <sup>3</sup> /(P·h)	29
Supply air requirement	m <sup>3</sup> /h	144
Extract air rooms		
Quantity		
Extract air requirement per room	m <sup>3</sup> /h	60
Total extract air requirement	m <sup>3</sup> /h	120
Design air flow rate (maximum)	m <sup>3</sup> /h	375
Recommended:		375 m <sup>3</sup> /h

Average air change rate calculation		Factors referenced to maximum		Air flow rate		Air change rate	
Type of operation	Daily operation times h/d			m <sup>3</sup> /h		1/h	
maximum	14.0	1.00		375		0.60	
Standard		0.38		144		0.23	
Basic ventilation		0.54		202		0.32	
Minimum	10.0	0.20		76		0.12	
Average value		0.67		Average air flow rate (m <sup>3</sup> /h)		Average air change rate (1/h)	
				250		0.40	

### Selection of ventilation unit with heat recovery

Location of ventilation unit **1-Inside thermal envelope**

Ventilation unit selection	Heat recovery efficiency	Humidity recovery efficiency	Specific efficiency [W/h·m <sup>2</sup> ]	Application [m <sup>3</sup> /h]	Frost power input
<a href="#">Go to ventilation units list</a> <a href="#">1-Scroll: LIKE LIST</a> <b>02ud-PRANA 150 PREMIUM PLUS MINI</b>	0.80	0.00	0.30	50 - 300	N/A
Conductivity outdoor air duct Ψ	W/(mK)	0.517		Implementation of frost protection	2-Elec.
Length of outdoor air duct	m	0		Limit temperature (°C)	-1
Conductivity exhaust air duct Ψ	W/(mK)	0.517		Useful energy [kWh/a]	575
Length of exhaust air duct	m	0		Room temperature (°C)	20
Temperature of mechanical services room	°C	20		Avg. ambient temp. heat. period (°C)	2.6
(Enter only if the central unit is outside of the thermal envelope)				Avg. ground temp (°C)	8.6

Effective heat recovery efficiency η<sub>HR,eff</sub> **80.0%**

### Effective heat recovery efficiency subsoil heat exchanger

SHX efficiency η<sup>\*</sup><sub>SHX</sub> **0%**  
Heat recovery efficiency SHX η<sub>SHX</sub> **0%**

Secondary calculation	
Ψ-value supply or outdoor air duct	
Nominal width	160 mm
Insulation thick	30 mm
Reflective coating?	<input checked="" type="checkbox"/> Yes
	<input type="checkbox"/> No
Thermal conductivity	0.038 W/(mK)
Nominal air flow rate	250 m <sup>3</sup> /h
Δθ	17 K
Exterior duct diameter	0.160 m
Exterior diameter	0.220 m
α-Interior	14.99 W/(m <sup>2</sup> K)
α-Surface	3.09 W/(m <sup>2</sup> K)
Ψ-value	0.517 W/(mK)
Surface temperature difference	4.198 K

Secondary calculation	
Ψ-value extract or exhaust air duct	
Nominal width:	160 mm
Insulation thickness:	30 mm
Reflective coating?	<input checked="" type="checkbox"/> yes
	<input type="checkbox"/> no
Thermal conductivity	0.038 W/(mK)
Nominal air flow rate	250 m <sup>3</sup> /h
Δθ	17 K
Exterior duct diameter	0.160 m
Exterior diameter	0.220 m
α-Interior	14.99 W/(m <sup>2</sup> K)
α-Surface	3.09 W/(m <sup>2</sup> K)
Ψ-value	0.517 W/(mK)
Surface temperature difference	4.198 K

# Heat distribution and domestic hot water (DHW) system

Energy balance calculation with PHPP Version 9.6a

Dzīvokļa māja / Climate: Rīga / TFA: 211 m² / Heating: 58.9 kWh/(m²a) / Freq. overheating: 2 % / PER: 131.8 kWh/(m²a)

Interior temperature:	20 °C	Interior temperature summer:	27 °C
Building type:	Dzīvokļa māja		
Treated floor area A <sub>int</sub> :	211 m²		
Occupancy:	5.0 Pers		
Number of dwelling units:	1		
Annual heating demand Q <sub>heating</sub> :	12409 kWh/a	Annual useful cooling dem. Q <sub>cool</sub> :	288 kWh/a
Length of heating period:	223 d	Length cooling period:	153 d
Average heating load P <sub>heating</sub> :	2.3 kW	Average cooling load P <sub>cooling</sub> :	0.1 kW
Marginal usability of additional heat gains:	98%	Marginal utility of additional heat losses:	2%

## Space heat distribution

	Inside thermal envelope					Outside thermal envelope					Total values	
	1	2	3	4	5	1	2	3	4	5	Absolute	Specific
Length of distribution pipes L <sub>dist</sub>	m	116.4										
Nominal width of pipe	mm	21										
Insulation thickness	mm	20										
Insulation reflective coating?	-	x										
Thermal conductivity of insulation	W/(mK)	0.040										
Heat loss coefficient per m of insulated pipe	W/(mK)	0.189										
Insulation quality of mountings, pipe suspensions, etc.	-	3 - Good	1-None	1-None	1-None	1-None	1-None	1-None	1-None	1-None		
Thermal bridge supplement	W/K	0.722										
Total heating loss coefficient per m of pipe	W/(mK)	0.195										
Temp. of the room through which the pipes pass	θ <sub>r</sub> °C	20	20	20	20	20						
Design forward flow temperature	θ <sub>f</sub> °C	55.0	55.0	55.0	55.0	55.0						
Design system heating load	P <sub>system</sub> kW	6.1	6.1	6.1	6.1	6.1						
Forward flow temperature control (x if appropriate)	-	x	x	x	x	x						
Design return flow temperature	θ <sub>r</sub> °C	45.0										
Annual heat emission per m of plumbing	q <sub>pl</sub> kWh/(m·a)	15										
Possible utilisation factor of released heat	f <sub>pl</sub>	98%										
Annual heat losses of heating distribution	Q <sub>dist</sub> kWh/a	30									30	0.1
Annual heat losses of heating storage	Q <sub>st</sub> kWh/a										0	0.0
Annual heat losses of heating	Q <sub>heating</sub> kWh/a										30	0.1
Performance ratio of heat distribution	PR <sub>dist</sub>										100%	

## DHW useful heat

DHW demand for showers, per person and day (with 60°C)	litre/person/d	16.0		
DHW demand others, per person and day (with 60°C)	litre/person/d	8.0		
Performance of shower drain-water heat recovery	-	0%		
Effective DHW demand	V <sub>DHW</sub> litre/person/d	25		
Average cold water temperature of the supply	θ <sub>pw</sub> °C	8.5		
DHW demand for washing machines and dishwashers	none	0		
Effective useful heat DHW	Q <sub>DHW</sub> kWh/a	2722		
			2722	12.9

### Auxiliary calculation - DHW demand calculation (for non-res)

### Auxiliary calculation - shower drain-water heat recovery

## DHW distribution

	Inside thermal envelope					Outside thermal envelope					Total values	
	1	2	3	4	5	1	2	3	4	5	Absolute	Specific
Temp. of room through which the pipes pass	θ <sub>r</sub> °C	20.0	20.0	20.0	20.0	20.0						
Design forward flow temperature	θ <sub>f,Dist</sub> °C	55.0	55.0	55.0	55.0	55.0						
DHW circulation pipes												
Length of circulation pipes (forward + return flow)	L <sub>circ</sub> m	24.0										
Nominal width of pipe	mm	21.00										
Insulation thickness	mm	9.00										
Insulation reflective coating?	-	x										
Thermal conductivity of insulation	W/(mK)	0.040										
Heat loss coefficient per m of insulated pipe	W/(mK)	0.304										
Insulation quality of mountings, pipe suspensions, etc.	-	3 - Good	1-None	1-None	1-None	1-None	1-None	1-None	1-None	1-None		
Thermal bridge supplement	W/K	0.250										
Total heating loss coefficient per m of pipe	ψ	0.315										
Daily circulation period of operation	t <sub>circ</sub> h/d	20.0										
Design return flow temperature	θ <sub>r</sub> °C	51										
Circulation period of operation per year	t <sub>circ</sub> h/a	7300										
Annual heat released per m of pipe	q <sub>2</sub> kWh/m·a	75										
Annual heat loss from circulation lines	Q <sub>2</sub> kWh/a	1609									1609	8.6
DHW individual losses												
Exterior pipe diameter	d <sub>1, ext</sub> m	0.016										
Accumulated length per single pipes	L <sub>1</sub> m	12.00										
Amount of tapping points in building	P <sub>tapping</sub> m	6.00										
Average pipe length per tapping point	L <sub>1, average</sub> m	2.0										
Tap openings per person per day	d	6										
Utilisation days per year	d	365										
Heat loss per tap opening	Q <sub>tap</sub> kWh/a	0.0122										
Amount of tap openings per year and person	n <sub>tap</sub> taps per year	2190										
Annual heat losses of individual pipes	Q <sub>1</sub> kWh/a	134									134	0.6
Total heat losses of DHW distribution	Q <sub>dist</sub> kWh/a										1943	9.2
Performance ratio of DHW distribution pipes	PR <sub>dist</sub>										171%	

## Storage heat losses

	Storage 1 1-DHW and heating	Storage 2 0-No storage tank	Buffer storage tank (only heating) 0-No storage tank	Compact unit 0-No		
Selection of storage tank	x		(x)			
Storage necessary for HP						
Solar DHW connection						
Heat loss rate	W/K	1.0	2.5			
Storage volume	litre	250				
Standby fraction						
Location of storage tank, inside or outside of thermal envelope	1-Inside	1-Inside	1-Inside			
Temperature of mechanical room	°C	20.0				
Typical storage tank temperature	°C	55.0				
Manual entry of storage temperature	°C					
Average standby heat losses storage tank	W	37				
Additional heat losses storage tank, solar operation	W					
Possible utilisation factor of heat losses						
Annual heat losses DHW storage tank	kWh/a	322				
Annual heat losses buffer storage tank						
Auxiliary calculation - heat losses through storage tank according to EU efficiency classes						
Storage tank volume	litre	250.0				
ErP classification		A	C			
Maximum permissible standby heat loss	W	47				
Heat loss ratio for PHPP calculation	W/K	1.0				
Total heat losses of DHW distribution and storage	Q <sub>dist</sub> kWh/a				2265	10.7
Performance ratio DHW-distribution + storage	PR <sub>dist</sub>				183%	
Total heating demand of DHW system	Q <sub>DHW</sub> kWh/a				4986	23.7

## Total energy demand of domestic hot water

Heat losses of DHW distribution and storage	Q <sub>dist</sub> kWh/a	2265	10.7
Performance ratio DHW-distribution + storage	PR <sub>dist</sub>	183%	
Total heating demand of DHW system	Q <sub>DHW</sub> kWh/a	4986	23.7

## Cooling distribution

	Inside thermal envelope					Outside thermal envelope					Total values	
	1	2	3	4	5	1	2	3	4	5	Absolute	Specific
Length of distribution pipes	L <sub>dist</sub> m											
Nominal width of pipe	mm											
Insulation thickness	mm											
Insulation reflective coating?	-											
Thermal conductivity of insulation	W/(mK)											
Heat loss coefficient per m pipe	ψ											
Temp. of room through which the pipes pass	θ <sub>r</sub> °C	27.0	27.0	27.0	27.0	27.0						
Design forward flow temperature	θ <sub>f</sub> °C	6.0	6.0	6.0	6.0	6.0						
Dimensioning of cooling load of the system	P <sub>cooling</sub> kW											
Forward flow temperature control (x if appropriate)	-											
Design return flow temperature	θ <sub>r</sub> °C											
Annual heat absorption per m of pipe	q <sub>pl</sub> kWh/(m·a)											
Possible utilisation factor of the heat absorption	f <sub>pl</sub>											
Annual heat losses of cooling distribution	Q <sub>cl</sub> kWh/a										0	0.0
Performance ratio cold water distribution pipes	PR <sub>cl</sub>										100%	

**CO2 emisiju un primārās enerģijas aprēķins**

Enerģijas patēriņa pakalpojums	Energonesējs	kWh/m <sup>2</sup> g	MWh/g	Sezonālās efektivitātes koeficients	CO <sub>2</sub> emisijas faktors, kgCO <sub>2</sub> /MWh	CO <sub>2</sub> emisijas kgCO <sub>2</sub>	f <sub>Pnren</sub>	f <sub>Pren</sub>	PE nren kWh/m <sup>2</sup> g	PE ren kWh/m <sup>2</sup> g	PE tot kWh/m <sup>2</sup> g	CO <sub>2</sub> emisijas kgCO <sub>2</sub> /m <sup>2</sup>
Apkure	Cietais biokurināmais	58.89	12.4093	0.85	40	584	0.20	1.00	13.86	69.28	83.14	2.77
	Elektroenerģija no tīkla	1.31	0.2757	1.00	109	30	1.90	0.60	2.49	0.78	3.27	0.14
Karstā ūdens sagatavošana	Cietais biokurināmais	23.66	4.9863	0.85	40	235	0.20	1.00	5.57	27.84	33.41	1.11
	Elektroenerģija no tīkla	0.71	0.1487	1.00	109	16	1.90	0.60	1.34	0.42	1.76	0.08
Karstā ūdens sagatavošana (papildu)	Elektroenerģija no tīkla	5.85	1.2324	1.00	109	134	1.90	0.60	11.11	3.51	14.62	0.64
Ventilācija	Elektroenerģija no tīkla	0.00	0.0000	1.00	109	0	1.90	0.60	0.00	0.00	0.00	0.00
Apgaisojums	Elektroenerģija no tīkla	0.00	0.0000	3.50	109	0	1.90	0.60	0.00	0.00	0.00	0.00
Dzesēšana	Elektroenerģija no tīkla	0.00	0.0000									
<b>KOPĀ:</b>		<b>90.4</b>	<b>19.0524</b>			<b>999</b>			<b>34.36</b>	<b>101.84</b>	<b>136.20</b>	<b>4.74</b>
					CO <sub>2</sub> emisijas kgCO <sub>2</sub> /m <sup>2</sup>	<b>4.74</b>						
					CO <sub>2</sub> emisijas tCO <sub>2</sub>	<b>1.00</b>						